

# ULTRA-ZONE®

## Forced Air Zone Controls


## SUBMITTAL SHEET

### Model ND Damper with MA-15S Actuator


The MA-15S motor actuator is easy to install, easy to wire up, and comes with a 5 year warranty. The superior design insures long life and zero maintenance. *The Motor can be oriented in any position in a conditioned area.* The UL Listed Motor Actuator is a 24vac 3 wire power open & power close type rated at 18 inch lbs. of torque and 15 second travel time. *The MA-15S can also operate in floating mode and is compatible with Carrier® Infinity & Bryant® Evolution communicating zone control systems.* The MA-15S includes an integrated wiring terminal block, and has a NEMA1 rated housing. Dual End-Stop adjustments allow for a maximum Open and Minimum Close field position capability.

#### Technical Data



Power Supply	24 VAC $\pm$ 20% 50/60Hz 24 VDC $\pm$ 10%
Power Consumption	1.5 W
Transformer Sizing	2.5 VA(Class 2 power source)
Electrical Connection	Screw Terminal (26 to 14 GA Wire)
Control Function	Open / Close or Floating Point
Torque	18 in-lb [2 Nm]
Manual Override	External Push Button
Running Time	15 seconds, constant independent of load
Humidity	5 to 95% RH Non-Condensing
Ambient Temperature	-22°F to +122°F [-30°C to +50°C]
Storage Temperature	-40°F to +176°F [-40°C to +80°C]
Housing	NEMA 1 / IP20
Housing Material	UL94-5VA
Agency Listings	cULus
Noise Level	45dB(A)



DIMENSIONAL  
DRAWINGS



Listed Size Less 3/16



Excellence Without Compromise

**EWC**®  
CONTROLS INC.

385 Hwy. 33  
Englishtown, NJ 07726  
Ph: 800-446-3110  
Fx: 732-446-5362

P/N 090377A0076 REV. D 1.11.18  
Copyright © 2006 EWC Controls Inc., All Rights Reserved.

#### SUBMITTAL FORM

SUBMITTED BY: \_\_\_\_\_

JOB: \_\_\_\_\_

ARCHITECT: \_\_\_\_\_

ENGINEER: \_\_\_\_\_

CONTRACTOR: \_\_\_\_\_

LOCATION: \_\_\_\_\_

# ULTRA-ZONE®

Forced Air Zone Controls

## SUBMITTAL SHEET

Model ND Damper  
with MA-15S Actuator

### Insertion Mounting

Cut a 4.25" slotted opening in one side of the duct and slide the damper in. Secure the damper to the duct with the sheet metal screws. Larger sizes may require additional support by securing the back of the damper as well. If using duct board, additional support can be obtained by using Model DBA Duct Board Adaptors.


***\*If flush wall mounting is required, cut the flanges off of the front mounting plate.***

### WIRING SOLUTIONS


#### Motor Actuator Terminals

TERMINAL	DESCRIPTION
1	24v Com.
4	Power Open
6	Power Close


#### Wiring to a Zone Control Panel



#### Wiring a Thermostat to Control a Single Damper



#### Wiring in Parallel



**NOTE:** You may electrically parallel several MA-15S motors together on a single zone. However, DO NOT parallel the MA-15S with original Carrier/Bryant damper motors on the same zone. The back-feed characteristic of the Carrier/Bryant motors is not compatible with the MA-15S motors.