


Warning Watchdog™

Condensing Unit Alarm System

iO-WWX



The Warning Watchdog is a condensing unit alarm system that sounds a loud siren and can also trigger a central alarm, phone dialer or other device. It can monitor up to 4 condensing units with one panel. This easy-to-install condensing unit alarm system can be used with packaged or split systems. It will alarm if refrigerant loss is detected, the disconnect is pulled or wiring is cut.



Warranty: 1 year

Warning Watchdog Packaged Hardwired Kits

| | |
|---------------|--|
| iO-WW1 | Logic panel with key lock, siren cut-off timer and siren silence switch Kit includes (1) iO-WWLP, (1) iO-WWPS, (1) iO-WWS, (1) iO-WWR240, (1) iO-WWPC |
| iO-WW2 | Logic panel with key lock, siren cut-off timer and siren silence switch Kit includes (1) iO-WWLP, (1) iO-WWPS, (1) iO-WWS, (2) iO-WWR240, (2) iO-WWPC |
| iO-WW3 | Logic panel with key lock, siren cut-off timer and siren silence switch Kit includes (1) iO-WWLP, (1) iO-WWPS, (1) iO-WWS, (3) iO-WWR240, (3) iO-WWPC |
| iO-WW4 | Logic panel with key lock, siren cut-off timer and siren silence switch Kit includes (1) iO-WWLP, (1) iO-WWPS, (1) iO-WWS, (4) iO-WWR240, (4) iO-WWPC |

Warning Watchdog Components and Optional Items

| | |
|------------------|--|
| iO-WWLP | Logic panel with key lock, siren cut-off timer and siren silence switch LEDs confirm alarm status |
| iO-WWPS | Power supply for iO-WWLP logic panel 12 volts DC - 1500mA |
| iO-WWPC | Encapsulated pressure control (mounts on liquid line schrader valve service port) Working pressure up to 600 PSI - 3500 PSI burst strength - opens in fall below 10 PSI |
| iO-WWR12 | Optional relay for additional siren. SPDT 12 volt DC relay |
| iO-WWR240 | Voltage monitoring relay - 240/208 volts Can be used with 240/208 single-phase or 3-phase |
| iO-WWR480 | Optional voltage monitoring relay - 440/480 volts Can be used with 440/480 3-phase |
| iO-WWS | Outdoor/indoor siren 12VDC 118dB output |
| iO-WWTS | Optional encapsulated tamper switch Detects excessive vibration or movement of condensing unit |
| iO-WWTAM | Optional Warning Watchdog tamper alert. Visual confirmation of open circuit |



5351 East Thompson Road Suite 142
Indianapolis, IN 46237
P: 888.359.0362
F: 317.489.5204
info@iOhvaccontrols.com
www.iOhvaccontrols.com